

September 30, 2021

Kinetic Reference No.: 8177-JB-R1

**Capilano University**

2055 Purcell Way  
North Vancouver, BC V7J 3H5

Email: nataliaskapski@capilanou.ca

**Attention: Natalia Skapski, Manager, Health & Safety**

**Reference: Lead Water Sampling – Arbutus Building,  
Cedar Building, Fitness Centre**



CSW,

## 1.0 Introduction

Kinetic OHS Services Ltd. (Kinetic OHS) has in accordance with your request, collected water samples from the above noted buildings at the Capilano University Campus located at 2055 Purcell Way, North Vancouver, BC. It is our understanding that elevated concentrations of lead in the drinking water have been a concern based on previous testing. The water samples were collected on Sunday, September 12, 2021 when classes were not in session.

## 2.0 Background on Lead in Drinking Water

Lead is a naturally occurring element found in small amounts in the earth's crust. Lead is a dense, odourless, bluish-grey heavy metal which is insoluble in water. Unlike other drinking water contaminants, lead is usually not in the water before it reaches the building. Lead can enter drinking water when plumbing materials that contain lead corrode including lead pipes, faucets and fixtures. Historically, lead was used extensively in service lines, solders and fittings. Water with high acidity or low mineral content especially corrodes pipes and fixtures thereby causing lead to leach from the systems.

Young children, infants, and fetuses are particularly vulnerable to lead because of the physical, behavioral and cognitive effects of lead. These effects can occur at a lower exposure level in children than in adults. Long term exposure to lead can cause it to accumulate in the bodies over time where it gets stored in the bones as a source of continual internal exposure. With age, when the bones demineralize, the bone tissue releases lead causing internal exposure. Lead can also cross the placental barrier thus pregnant women who are exposed to lead can also expose their fetus. Even at extremely low levels, exposure to lead can be toxic and very difficult to eliminate from the body.

Prolonged exposure to lead can cause abdominal pain, constipation, depression, forgetfulness, irritability, and nausea/sickness. People with prolonged exposure to lead are also at a risk for high blood pressure, heart disease, kidney disease, and reduced fertility. In children, lead exposure has been determined to cause adverse cognitive and behavioural effects especially reduction of intelligence quotient (IQ) scores.

Lead cannot be detected in water by sight, smell or taste. Discoloration episodes such as red water are likely to be accompanied by the release of accumulated contaminants including lead as dissolved lead adsorbs onto iron deposits in the lead service line. However, discoloration does not always accompany lead contamination. Hence, testing is the only way to detect lead in water.

## **2.0 Scope of Work**

Kinetic OHS collected water samples for the cold water tap from faucets and drinking fountains in various buildings across the campus. The locations to be tested were determined by Capilano University. The results were compared against the current Canadian Drinking Water Guidelines.

## **3.0 Observations**

The faucets and drinking fountains were noted to be in relatively good condition. Signage was posted at each faucet of concern not to use the water until the water has been tested. No unusual odours or discoloration of the water that would indicate contamination from other agents was noted during the sampling.

## **4.0 Sampling Methodology**

Sampling was performed by collecting the water in a 125 mL wide mouth sample bottle. Refer to Appendix A for maps of sample locations.

To capture a worst case scenario, the samples were collected on a Sunday morning with no prior flushing which allowed for a stagnation period. A second water sample was collected from each source after running the water for 5 minutes.

The water samples were submitted to Bureau Veritas Laboratories in Burnaby for analysis using the validated analytical method indicated in the analytical results (Appendix B). A total of 24 water samples were collected and analyzed for Lead.

The Maximum Acceptable Concentration (MAC) for total lead in drinking water based on the Canadian Drinking Water Quality Guidelines is 0.005 mg/L (5 µg/L). The World Health Organization recommends that every effort should be made to reduce levels in drinking water to As Low As Reasonably Achievable (ALARA).

## **4.0 Results**

The results of the sampling are summarized in Table 1. Three of the initial samples collected after stagnation were above the MAC of lead. These samples were collected from the Birch Building Room 257 (office faucet), the Cedar Building Room 131 (storage room faucet) and CWS Room 107, Storage Room, Cooler Fill. All samples found that after running the water for 5 minutes the levels were below the MAC.

Averages of the two sample results were also calculated for each faucet and are shown in Table 1. For those results where the result was less than the detection limit, the detection limit was used to calculate

the average, which would likely result in a much higher concentration than the true average. Refer to Appendix B for laboratory analytical results.

**Table 1: Lead Results**

Sample Number	Building	Sample Location	Lead Concentration (mg/L)	Average Lead Concentration (mg/L)
8177-01	Arbutus Building	Room 206 – Kitchen Faucet	0.0046	0.0025
8177-02			0.00039	
8177-03	Birch Building	Room 257 – Office Faucet	<b>0.030</b>	<b>0.016</b>
8177-04			0.0015	
8177-05	Cedar Building	Room 339 – Staff Room Faucet	0.0011	0.0007
8177-06			<0.0002	
8177-07	Cedar Building	Room 131 – Storage Room Faucet	<b>0.015</b>	<b>0.0076</b>
8177-08			0.00022	
8177-09	Fir Building	Room 119 – Music Therapy Room Faucet	0.0009	0.00055
8177-10			<0.0002	
8177-11	Fir Building	Room 302D – Physics Lab Faucet	0.00033	0.00027
8177-12			<0.0002	
8177-13	Fir Building	Room 309A – Biology Lab Faucet	0.00093	0.00057
8177-14			<0.0002	
8177-15	Library	Room 323 – Kitchen Faucet	0.001	0.00065
8177-16			0.0003	
8177-17	CSW	Room 107 – Storage Room Cooler Fill	<b>0.0073</b>	0.0038
8177-18			0.00035	
8177-19	CSW	Weight Room – Concession – 111A Double Sink	0.00086	0.00053
8177-20			<0.0002	
8177-21	Fitness Centre	Men’s Change Room – 102 Fountain	0.0015	0.00085
8177-22			<0.0002	
8177-23	Fitness Centre	Men’s Change Room – 102 Bottle Fill Station	0.00023	0.00022
8177-24			<0.0002	

**Notes**

- “<” = Less than detection limit
- **Grey Shading**= Maximum Acceptable Concentration (MAC) of 0.005 µg/L exceeded
- The first sample listed for each location was collected after stagnation, the second sample was collected after running the water for 5 minutes.

## 5.0 Conclusions & Recommendations

A total of 24 water samples were collected from various water sources on campus and compared to the Canadian Drinking Water Quality guidelines published by Health Canada. Three of the samples had elevated levels of lead in the initial sample collected after a stagnation period, but all had acceptable levels after the water was allowed to run for five minutes.

The results of the two samples collected at each water source were averaged and the averages identified showed two locations with averages above the MAC for lead. These locations were.

- Birch Building – Room 257 – Office Faucet
- Cedar Building – Room 131 – Storage Room Faucet

Calculating the average of two drinking may be valuable if the water source were to be used for a prolonged period, such as to fill a cooler; however, we do not know when the level of lead in the drinking water decreased to acceptable levels, and levels may be acceptable even after 30 seconds of running the stagnated water, therefore, the averages may not be representative of actual drinking water conditions.

Those taps with elevated lead levels after stagnation must be further investigated and/or signage posted to either the run the water prior to drinking or “Do not drink from tap”. Hand washing does not pose a risk of exposure because lead in water is not readily absorbed through human skin via dermal exposure.

As the stagnation samples were collected to represent a worse-case scenario, random daytime sampling could be considered the point sources with elevated lead levels to determine if the lead is elevated during the day during normal use.

It must be noted that municipal treatment of water to remove lead may not be the most effective strategy because lead is most likely released by corrosion in the local plumbing and distribution systems. Moreover, treatment technologies can change water quality parameters that impact lead release thereby increasing lead in drinking water. Hence, long term strategies to mitigate lead exposures must be focused on replacing local plumbing and distribution systems.

Health Canada Guideline of Drinking Water Quality recommends that the total lead in schools and daycares be monitored at least once a year at each of the drinking water fountains or cold water taps where water may be used for drinking or food preparation.

## 6.0 Limitations

This report has been prepared in accordance with established Industrial Hygiene practices. It is intended for the exclusive use of the client to assist with complying with the current accepted industry guidelines for the assessment of drinking water based on the Canadian Drinking Water Guidelines. The use of this document for any other purposes is at the sole risk of the user.

We thank you for having Kinetic OHS Services conduct this work for you. Should you have any questions, please contact us at your earliest convenience.

Sincerely,

### Kinetic OHS Services Ltd.



---

Jeff Lee, B.Tech. OHS Technologist  
AHERA Building Inspector (CABI-20-060)  
Site Investigation  
Email: [jeff@kineticohs.com](mailto:jeff@kineticohs.com)



---

Jennifer Blair, MSc, CIH  
Manager, Industrial Hygiene  
Report Review  
Email: [jennifer@kineticohs.com](mailto:jennifer@kineticohs.com)  
Cell: 604-816-5711



---

Harvey Wong, CRSP, ROHT  
Director/Principal Consultant  
Report Review  
Email: [harvey@kineticohs.com](mailto:harvey@kineticohs.com)  
Cell: 604-816-1290


File Reference: 8177-JB-R1 - Capilano University - Lead Water Sampling Report

## Appendix A – Maps of Sample Locations



**CAPILANO  
UNIVERSITY**


2055 PURCELL WAY  
NORTH VANCOUVER, BC  
CANADA V7J 3H5



## **ARBUTUS BUILDING SECOND FLOOR**



2055 PURCELL WAY  
NORTH VANCOUVER, BC  
CANADA V7J 3H5




**BIRCH BUILDING | SECOND FLOOR**




**CAPILANO  
UNIVERSITY**

2055 PURCELL WAY  
NORTH VANCOUVER, BC  
CANADA V7J 3H5



## CEDAR BUILDING | THIRD FLOOR






**CEDAR BUILDING | FIRST FLOOR**




2055 PURCELL WAY  
NORTH VANCOUVER, BC  
CANADA V7J 3H5



# FIR BUILDING | FIRST FLOOR

13 14




11 12

**FIR BUILDING | THIRD FLOOR**




2055 PURCELL WAY  
NORTH VANCOUVER BC  
CANADA V7J 3H5



# LIBRARY BUILDING | THIRD FLOOR



2055 PURCELL WAY  
NORTH VANCOUVER, BC  
CANADA V7J 3H5




# SPORTSPLEX BUILDING | FIRST FLOOR



**CAPILANO**  
UNIVERSITY

2055 PURCELL WAY  
NORTH VANCOUVER, BC  
CANADA V7J 3H5



## FITNESS CENTRE BUILDING | GROUND FLOOR

## Appendix B – Analytical Results for Lead Water Samples



Your Project #: 8177-IB  
 Site Location: CAPILANO UNIVERSITY

Attention: Jeff Lee  
 KINETIC OHS SERVICES LTD.  
 #202 – 1520 Barrow Street  
 NORTH VANCOUVER, BC  
 CANADA V7J 1B7

Your C.O.C. #: 647320-01-01, 647320-02-01, 647320-06-01

Report Date: 2021/09/20  
 Report #: R3073824  
 Version: 1 - Final

### CERTIFICATE OF ANALYSIS

BV LABS JOB #: C168121  
 Received: 2021/09/13, 17:25  
 Sample Matrix: Drinking Water  
 # Samples Received: 24

Analyses	Quantity	Date	Date	Laboratory Method	Analytical Method
		Extracted	Analyzed		
Lead in Drinking Water	20	2021/09/15	2021/09/15	AB SOP-00014 / AB SOP-00043	EPA 6020b R2 m
Lead in Drinking Water	4	2021/09/16	2021/09/16	AB SOP-00014 / AB SOP-00043	EPA 6020b R2 m

Remarks:

Bureau Veritas is accredited to ISO/IEC 17025 for specific parameters on scopes of accreditation. Unless otherwise noted, procedures used by Bureau Veritas are based upon recognized Provincial, Federal or US method compendia such as CCME, MELCC, EPA, APHA.

All work recorded herein has been done in accordance with procedures and practices ordinarily exercised by professionals in Bureau Veritas' profession using accepted testing methodologies, quality assurance and quality control procedures (except where otherwise agreed by the client and Bureau Veritas in writing). All data is in statistical control and has met quality control and method performance criteria unless otherwise noted. All method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Where applicable, unless otherwise noted, Measurement Uncertainty has not been accounted for when stating conformity to the referenced standard.

Bureau Veritas liability is limited to the actual cost of the requested analyses, unless otherwise agreed in writing. There is no other warranty expressed or implied. Bureau Veritas has been retained to provide analysis of samples provided by the Client using the testing methodology referenced in this report. Interpretation and use of test results are the sole responsibility of the Client and are not within the scope of services provided by Bureau Veritas, unless otherwise agreed in writing. Bureau Veritas is not responsible for the accuracy or any data impacts, that result from the information provided by the customer or their agent.

Solid sample results, except biota, are based on dry weight unless otherwise indicated. Organic analyses are not recovery corrected except for isotope dilution methods.

Results relate to samples tested. When sampling is not conducted by Bureau Veritas, results relate to the supplied samples tested.

This Certificate shall not be reproduced except in full, without the written approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

\* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.



Your Project #: 8177-JB  
Site Location: CAPILANO UNIVERSITY

**Attention: Jeff Lee**  
KINETIC OHS SERVICES LTD.  
#202 – 1520 Barrow Street  
NORTH VANCOUVER, BC  
CANADA V7J 1B7

Your C.O.C. #: 647320-01-01, 647320-02-01, 647320-06-01

Report Date: 2021/09/20  
Report #: R3073824  
Version: 1 - Final

### CERTIFICATE OF ANALYSIS

**BV LABS JOB #: C168121**  
Received: 2021/09/13, 17:25

Encryption Key



**AUTHORIZED REPORT**  
**RAPPORT AUTORISÉ**

Bureau Veritas  
20 Sep 2021 13:41:53

Please direct all questions regarding this Certificate of Analysis to your Project Manager.  
Customer Solutions, Western Canada Customer Experience Team  
Email: customersolutionswest@bureauveritas.com  
Phone# (604) 734 7276

=====

This report has been generated and distributed using a secure automated process.  
BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.





BV Labs Job #: C168121  
Report Date: 2021/09/20

KINETIC OHS SERVICES LTD.  
Client Project #: 8177-JB  
Site Location: CAPILANO UNIVERSITY  
Sampler Initials: JL

**ELEMENTS BY ATOMIC SPECTROSCOPY (DRINKING WATER)**

BV Labs ID			AFW001	AFW002	AFW003		
Sampling Date			2021/09/12 07:00	2021/09/12 07:00	2021/09/12 07:00		
COC Number			647320-01-01	647320-01-01	647320-01-01		
	UNITS	MAC	8177-1 ARBUTUS BLDG. RM 206 KITCHEN FAUCET	8177-2 ARBUTUS BLDG. RM 206 KITCHEN FAUCET	8177-3 BIRCH BUILDING RM 257 OFFICE FAUCET	RDL	QC Batch
<b>Elements</b>							
Total Lead (Pb)	mg/L	0.005	0.0046	0.00039	0.030	0.00020	A352824
No Fill	No Exceedance						
Grey	Exceeds 1 criteria policy/level						
Black	Exceeds both criteria/levels						
RDL = Reportable Detection Limit							
BV Labs ID			AFW004	AFW005	AFW006		
Sampling Date			2021/09/12 07:00	2021/09/12 07:00	2021/09/12 07:00		
COC Number			647320-01-01	647320-01-01	647320-01-01		
	UNITS	MAC	8177-4 BIRCH BUILDING RM 257 OFFICE FAUCET	8177-5 CEDAR BUILDING RM 339 STAFF RM FAUCET	8177-6 CEDAR BUILDING RM 339 STAFF RM FAUCET	RDL	QC Batch
<b>Elements</b>							
Total Lead (Pb)	mg/L	0.005	0.0015	0.0011	<0.00020	0.00020	A352824
No Fill	No Exceedance						
Grey	Exceeds 1 criteria policy/level						
Black	Exceeds both criteria/levels						
RDL = Reportable Detection Limit							
BV Labs ID			AFW007	AFW008	AFW009		
Sampling Date			2021/09/12 07:00	2021/09/12 07:00	2021/09/12 07:00		
COC Number			647320-01-01	647320-01-01	647320-01-01		
	UNITS	MAC	8177-7 CEDAR BUILDING STORAGE RM 131 FAUCET	8177-8 CEDAR BUILDING STORAGE RM 131 FAUCET	8177-9 FIR BUILDING RM 119 MUSIC RM FAUCET	RDL	QC Batch
<b>Elements</b>							
Total Lead (Pb)	mg/L	0.005	0.015	0.00022	0.00090	0.00020	A352824
No Fill	No Exceedance						
Grey	Exceeds 1 criteria policy/level						
Black	Exceeds both criteria/levels						
RDL = Reportable Detection Limit							



BV Labs Job #: C168121  
Report Date: 2021/09/20

KINETIC OHS SERVICES LTD.  
Client Project #: 8177-JB  
Site Location: CAPILANO UNIVERSITY  
Sampler Initials: JL

**ELEMENTS BY ATOMIC SPECTROSCOPY (DRINKING WATER)**

BV Labs ID			AFW010	AFW011	AFW012		
Sampling Date			2021/09/12 07:00	2021/09/12 07:00	2021/09/12 07:00		
COC Number			647320-01-01	647320-02-01	647320-02-01		
	UNITS	MAC	8177-10 FIR BUILDING RM 119 MUSIC RM FAUCET	8177-11 FIR BUILDING RM 602D PHYSICS FAUCET	8177-12 FIR BUILDING RM 602D PHYSICS FAUCET	RDL	QC Batch

Elements							
Total Lead (Pb)	mg/L	0.005	<0.00020	0.00033	<0.00020	0.00020	A352824
No Fill	No Exceedance						
Grey	Exceeds 1 criteria policy/level						
Black	Exceeds both criteria/levels						
RDL = Reportable Detection Limit							

BV Labs ID			AFW013	AFW014	AFW015		
Sampling Date			2021/09/12 07:00	2021/09/12 07:00	2021/09/12 07:00		
COC Number			647320-02-01	647320-02-01	647320-02-01		
	UNITS	MAC	8177-13 FIR BUILDING RM 309 BIOLOGY FAUCET	8177-14 FIR BUILDING RM 309 BIOLOGY FAUCET	8177-15 LIBRARY RM 323 KITCHEN	RDL	QC Batch

Elements							
Total Lead (Pb)	mg/L	0.005	0.00093	<0.00020	0.0010	0.00020	A352824
No Fill	No Exceedance						
Grey	Exceeds 1 criteria policy/level						
Black	Exceeds both criteria/levels						
RDL = Reportable Detection Limit							

BV Labs ID			AFW016	AFW017	AFW018		
Sampling Date			2021/09/12 07:00	2021/09/12 07:00	2021/09/12 07:00		
COC Number			647320-02-01	647320-02-01	647320-02-01		
	UNITS	MAC	8177-16 LIBRARY RM 323 KITCHEN	8177-17 CSW STORAGE RM COOLER FILL	8177-18 CSW STORAGE RM COOLER FILL	RDL	QC Batch

Elements							
Total Lead (Pb)	mg/L	0.005	0.00030	0.0073	0.00035	0.00020	A352824
No Fill	No Exceedance						
Grey	Exceeds 1 criteria policy/level						
Black	Exceeds both criteria/levels						
RDL = Reportable Detection Limit							



BV Labs Job #: C168121  
 Report Date: 2021/09/20

KINETIC OHS SERVICES LTD.  
 Client Project #: 8177-JB  
 Site Location: CAPILANO UNIVERSITY  
 Sampler Initials: JL

**ELEMENTS BY ATOMIC SPECTROSCOPY (DRINKING WATER)**

BV Labs ID			AFW019	AFW020		AFW022		
Sampling Date			2021/09/12 07:00	2021/09/12 07:00		2021/09/12 07:00		
COC Number			647320-02-01	647320-02-01		647320-06-01		
	UNITS	MAC	8177-19 CSW WEIGHT ROOM CONCESSION DOUBLE SINK	8177-20 CSW WEIGHT ROOM CONCESSION DOUBLE SINK	QC Batch	8177-21 CSW MENS CHANGE RM FOUNTAIN	RDL	QC Batch
<b>Elements</b>								
Total Lead (Pb)	mg/L	0.005	0.00086	<0.00020	A352824	0.0015	0.00020	A354549
No Fill	No Exceedance							
Grey	Exceeds 1 criteria policy/level							
Black	Exceeds both criteria/levels							
RDL = Reportable Detection Limit								

BV Labs ID			AFW023	AFW024	AFW025		
Sampling Date			2021/09/12 07:00	2021/09/12 07:00	2021/09/12 07:00		
COC Number			647320-06-01	647320-06-01	647320-06-01		
	UNITS	MAC	8177-22 CSW MENS CHANGE RM FOUNTAIN	8177-23 CSW MENS CHANGE RM FILLER STN	8177-24 CSW MENS CHANGE RM FILLER STN	RDL	QC Batch
<b>Elements</b>							
Total Lead (Pb)	mg/L	0.005	<0.00020	0.00023	<0.00020	0.00020	A354549
No Fill	No Exceedance						
Grey	Exceeds 1 criteria policy/level						
Black	Exceeds both criteria/levels						
RDL = Reportable Detection Limit							



BUREAU  
VERITAS

BV Labs Job #: C168121  
Report Date: 2021/09/20

KINETIC OHS SERVICES LTD.  
Client Project #: 8177-JB  
Site Location: CAPILANO UNIVERSITY  
Sampler initials: JL

#### GENERAL COMMENTS

MAC: The guidelines that have been included in this report have been taken from the Canadian Drinking Water Quality Summary Table, September 2020.

Criteria A = Maximum Acceptable Concentration (MAC) / Criteria B = Aesthetic Objectives (AO) / Criteria C = Operational Guidance Values (OG)  
It is recommended to consult these guidelines when interpreting your data since there are non-numerical guidelines that are not included on this report.

**Turbidity Guidelines:**

1. Chemically assisted filtration: less than or equal to 0.3 NTU in 95% of the measurements or 95% of the time each month. Shall not exceed 1.0 NTU at any time.
  2. Slow sand / diatomaceous earth filtration: less than or equal to 1.0 NTU in 95% of the measurements or 95% of the time each month. Shall not exceed 3.0 NTU at any time.
  3. Membrane filtration: less than or equal to 0.1 NTU in 99% of the measurements made or at least 99% of the time each calendar month. Shall not exceed 0.3 NTU at any time.
  4. To ensure effectiveness of disinfection and for good operation of the distribution system, it is recommended that water entering the distribution system have turbidity levels of 1.0 NTU or less.
- Measurement of Uncertainty has not been accounted for when stating conformity to the selected criteria, where applicable.

**Results relate only to the items tested.**



BV Labs Job #: C168121  
Report Date: 2021/09/20

**QUALITY ASSURANCE REPORT**

KINETIC OHS SERVICES LTD.  
Client Project #: 8177-JB  
Site Location: CAPILANO UNIVERSITY  
Sampler Initials: JL

QC Batch	Parameter	Date	Matrix Spike		Spiked Blank		Method Blank		RPD	
			% Recovery	QC Limits	% Recovery	QC Limits	Value	UNITS	Value (%)	QC Limits
A352824	Total Lead (Pb)	2021/09/15	110	80 - 120	107	80 - 120	<0.00020	mg/L	0.63	20
A354549	Total Lead (Pb)	2021/09/15	98	80 - 120	104	80 - 120	<0.00020	mg/L	1.5	20

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.

Matrix Spike: A sample to which a known amount of the analyte of interest has been added. Used to evaluate sample matrix interference.

Spiked Blank: A blank matrix sample to which a known amount of the analyte, usually from a second source, has been added. Used to evaluate method accuracy.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.



BUREAU  
VERITAS

BV Labs Job #: C168121  
Report Date: 2021/09/20

KINETIC OHS SERVICES LTD.  
Client Project #: 8177-JB  
Site Location: CAPILANO UNIVERSITY  
Sampler Initials: JL

### VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by:

David Huang, M.Sc., P.Chem., QP, Scientific Services Manager

---

BV Labs has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

10/1/03

**Client Information**

Company Name: #1146 MINETEC OHS SERVICES LTD  
 Contact Name: Accounts Payable  
 Address: 8202 - 1520 Beaver Street  
 NORTH VANCOUVER BC V7J 1B7  
 Phone: (604) 986-0099  
 Email: info@minetec.com harvey@minetec.com

**Project Information**

Company: C-3006  
 Project ID: 8177-09  
 Project Name: Supermarket Development  
 Contact: John Doe

**Barcode**

C168121\_COC

---

**Regulatory Criteria**

OHS  
 OHS  
 BC Water Quality  
 Other: N/A

Sample Barcode Label	Sample Location/Identification	Date Collected	Time Collected	Notes
8177-1	Room 206 Kitchen Area	2001/4/12	7:00	
8177-2				
8177-3	Room 207 Office Area			
8177-4				
8177-5	Room 207 Office Area			
8177-6				
8177-7	Room 207 Office Area			
8177-8				
8177-9	Room 115 Main Reception			
8177-10				

**Additional Information**

Regular (Standard) Test:   
 Standard Test = 5.7 Minimum Value for Lead Lead:   
 Project Note: Supermarket Development  
 Job Specific Form:  1 Day  2 Day  3 Day  4 Day  5 Day  6 Day  7 Day  8 Day  9 Day  10 Day  11 Day  12 Day  13 Day  14 Day  15 Day  16 Day  17 Day  18 Day  19 Day  20 Day  21 Day  22 Day  23 Day  24 Day  25 Day  26 Day  27 Day  28 Day  29 Day  30 Day  31 Day  32 Day  33 Day  34 Day  35 Day  36 Day  37 Day  38 Day  39 Day  40 Day  41 Day  42 Day  43 Day  44 Day  45 Day  46 Day  47 Day  48 Day  49 Day  50 Day  51 Day  52 Day  53 Day  54 Day  55 Day  56 Day  57 Day  58 Day  59 Day  60 Day  61 Day  62 Day  63 Day  64 Day  65 Day  66 Day  67 Day  68 Day  69 Day  70 Day  71 Day  72 Day  73 Day  74 Day  75 Day  76 Day  77 Day  78 Day  79 Day  80 Day  81 Day  82 Day  83 Day  84 Day  85 Day  86 Day  87 Day  88 Day  89 Day  90 Day  91 Day  92 Day  93 Day  94 Day  95 Day  96 Day  97 Day  98 Day  99 Day  100 Day

---

Please Refer to Back of Form for Instructions

Page 2 of 3

<b>CLIENT INFORMATION</b> Project Name: #1488 - ANETHIC CHS SERVICES LTD Account Name: Accounts Payable Address: #202 - 1520 Bannock Street NORTH VANCOUVER BC V2J 1R7 Phone: (604) 688-0099 Email: accounts@anethic.com		<b>REPORT INFORMATION</b> Sampling Name: Sanitary Swab Address: 1520 Bannock Street Phone: (604) 688-0099 Email: accounts@anethic.com		<b>PROJECT INFORMATION</b> Location: C1004 Project ID: C168123_COC Date of Sample Receipt: 2012-08-14 Project Manager:																																																								
<b>REPORTING OPTIONS</b> <input type="checkbox"/> CLM <input type="checkbox"/> OCM <input type="checkbox"/> Bacterial Quality <input checked="" type="checkbox"/> Other: N/A		<b>LABORATORY INFORMATION</b> Lab Name:		<b>CONTAMINANT TYPE (AND) REQUIRED</b> Report (Standard) TAT: <input checked="" type="checkbox"/> Will be reported if level TAT is not reported: <input type="checkbox"/> Standard TAT: 5-7 working days for most tests Please note: Standard TAT for water tests is 10-15 working days for 7-8 days - contact your Project Manager for details. Job Reports: Please FAX or e-mail to your administrator: FAX: <input type="checkbox"/> or E-mail: <input type="checkbox"/> Check Required: <input type="checkbox"/> Name: <input type="checkbox"/> Title: <input type="checkbox"/>																																																								
SAMPLES MUST BE KEPT COOL (1-4°C) FROM TIME OF SAMPLING UNTIL DELIVERY TO BY LABS																																																												
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Sample Number (Lab)</th> <th>Sample Location / Description</th> <th>Date Sampled</th> <th>Time Sampled</th> <th>Notes</th> </tr> </thead> <tbody> <tr> <td>8177-11</td> <td>1st Washdown Sanitary Swab</td> <td>2012/8/12</td> <td>7:00</td> <td></td> </tr> <tr> <td>8177-12</td> <td>"</td> <td></td> <td></td> <td></td> </tr> <tr> <td>8177-13</td> <td>1st Washdown Sanitary Swab</td> <td></td> <td></td> <td></td> </tr> <tr> <td>8177-14</td> <td>"</td> <td></td> <td></td> <td></td> </tr> <tr> <td>8177-15</td> <td>2nd Washdown Sanitary Swab</td> <td></td> <td></td> <td></td> </tr> <tr> <td>8177-16</td> <td>"</td> <td></td> <td></td> <td></td> </tr> <tr> <td>8177-17</td> <td>2nd Washdown Sanitary Swab</td> <td></td> <td></td> <td></td> </tr> <tr> <td>8177-18</td> <td>"</td> <td></td> <td></td> <td></td> </tr> <tr> <td>8177-19</td> <td>3rd Washdown Sanitary Swab</td> <td></td> <td></td> <td></td> </tr> <tr> <td>8177-20</td> <td>"</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>						Sample Number (Lab)	Sample Location / Description	Date Sampled	Time Sampled	Notes	8177-11	1st Washdown Sanitary Swab	2012/8/12	7:00		8177-12	"				8177-13	1st Washdown Sanitary Swab				8177-14	"				8177-15	2nd Washdown Sanitary Swab				8177-16	"				8177-17	2nd Washdown Sanitary Swab				8177-18	"				8177-19	3rd Washdown Sanitary Swab				8177-20	"			
Sample Number (Lab)	Sample Location / Description	Date Sampled	Time Sampled	Notes																																																								
8177-11	1st Washdown Sanitary Swab	2012/8/12	7:00																																																									
8177-12	"																																																											
8177-13	1st Washdown Sanitary Swab																																																											
8177-14	"																																																											
8177-15	2nd Washdown Sanitary Swab																																																											
8177-16	"																																																											
8177-17	2nd Washdown Sanitary Swab																																																											
8177-18	"																																																											
8177-19	3rd Washdown Sanitary Swab																																																											
8177-20	"																																																											
<b>ANALYSIS INFORMATION</b> Date of Analysis: 2012/08/14 Time of Analysis: 7:00		<b>LABORATORY INFORMATION</b> Lab Name:		<b>LABORATORY USE ONLY</b> Temperature (°C) or (°F): Other:																																																								

\* USE OF THIS FORM IS SUBJECT TO THE TERMS AND CONDITIONS OF THE STANDARD SERVICE AGREEMENT. THE USER OF THIS FORM IS SUBJECT TO THE TERMS AND CONDITIONS OF THE STANDARD SERVICE AGREEMENT. THE USER OF THIS FORM IS SUBJECT TO THE TERMS AND CONDITIONS OF THE STANDARD SERVICE AGREEMENT.



1000343

**INVOICE TO**

Company Name: **81466 KINETIC OHS SERVICES LTD**

Account Name: **Accounts Payable**

Address: **2021 - 1520 Banack Street**

Phone: **604-588-0099**

Fax: **604-588-0099**

Website: **www.kineticohs.com**

**Project Information**

Customer: **C-0066**

Project #: **5177-03**

Project Name: **Coastline University**

Site #: **200-105**

Barcode: **C168121\_COC**

**Frequency/Volume**

COT

CCM

30 Water-Flush

Other: **N/A**

Sample Barcode Label	Sample Location/Description	Date for next	Time for next	Other	Notes
8177-21	Cow Milk Collection Point	2011/9/12	7:00		
8177-22	"				
8177-23	Cow Milk Collection Point				
8177-24	Filler Station				

**RECEIVED BY:** *[Signature]* Date: **2011/11/17** Time: **12:35**

**LAB USE ONLY**

Temperature (C) or (F): **15.11/57**

Time: **15/11/11**

